



## BRIDGE B-581

### HAZARDOUS MATERIALS SURVEY

BRIDGE INSPECTION AND SURVEY FOR PRESENCE OF  
ASBESTOS AND HEAVY METAL(S),  
JULY 2021

NDOT Hazardous Materials Section, Environmental Division

1263 South Stewart Drive  
Carson City, NV 89712

## **EXECUTIVE SUMMARY**

The inspection (survey) for hazardous materials was conducted on bridge B-581 on July 6, 2021, by NDOT personnel from the Hazardous Materials section, of the Environmental Division. The bridge was evaluated for both asbestos containing materials (ACM) and heavy metals in coating materials. One suspect metals sample and thirteen suspect asbestos samples were collected with results and considerations summarized below:

- No ACMs were identified
- Heavy metals were found in coating material but are not considered Lead-Based Paint

## 1.0 INTRODUCTION

NDOT conducted an asbestos survey and screening for metals-based coating materials on the following bridge structure located in Elko County:

- B-581 (Humboldt River near Carlin, SR-278)

The survey was conducted on July 6, 2021, by NDOT personnel. Suspect Asbestos Containing Material (ACM) were identified and appropriately sampled. Coating materials, if present, were sampled and analyzed for the Resource Recovery and Conservation Act seven (RCRA 7) metals.

Bulk asbestos samples were analyzed by a National Voluntary Laboratory Accredited laboratory by polarized light microscopy (PLM). Metals analysis was conducted by a Nevada Certified Lab. The results of the laboratory analysis are attached as Appendix C and Appendix D, respectively.

## 2.0 BRIDGE DESCRIPTION

Bridge B-581 was constructed in 1954 with subsequent rehabilitative work in 1996. The bridge in its entirety is constructed of concrete to include; beams, piers, abutments, parapet coated in white textured material, and bridge deck overlain with asphaltic concrete.

## 3.0 FIELD ACTIVITIES

The survey was conducted by NDOT personnel, appropriately licensed Asbestos and Hazardous Emergency Response Act (AHERA) accredited asbestos inspectors. The survey was conducted in general accordance with the sample collection protocols established in EPA regulation 40 CFR 763. A summary of the survey activities performed is discussed below. Copies of AHERA certifications and licenses for NDOT personnel conducting the survey are provided as Appendix E.

### 3.1 Visual and Physical Assessment

Survey activities began with a visual observation of the structures to identify homogeneous areas of suspect ACM and presence of coating materials. A physical assessment of each homogeneous area of suspect ACM was conducted to assess the friability and condition of the materials.

The homogeneous areas identified during the visual survey, the presence of coating materials, and sample identifiers are summarized in Table 1.

**Table 1 - Bridge Component Descriptions**

Homogeneous Area	Description	Sample IDs
A	parapet	Para-1, Para-2, Para-3
B	bridge deck and beams	Bridge-1, Bridge-2, Bridge-3
C	abutment	Abut-1, Abut-2, Abut-3
D	piers	Pier-1, Pier-2, Pier-3
E	coating texture material, parapet (composite)	Text, Text-581 <sup>(1)</sup>

notes: (1) metal analysis identifier.

### **3.2 Sample Collection**

Based on results of the visual observation, bulk samples of suspect ACM and coating materials were collected in general accordance with AHERA sampling protocols. Representative samples of suspect materials were collected in each homogeneous area. Samples were placed in new sealable containers and labeled with unique sample numbers.

### **3.3 Sample Analysis**

Bulk samples of ACM were submitted under chain of custody to Asbestos TEM Laboratories for analysis by PLM. The percentage of asbestos, where applicable, was determined by microscopic visual estimation. Coating material samples were also submitted to Alpha Analytical and analyzed for heavy metals using EPA 6020 test method.

A discussion of suspect ACM and suspect metals-based coating samples collected during the survey and findings are included in Section 6.0.

## **4.0 PLAN REVIEW**

Original design plans were not available for review.

## **5.0 REGULATORY OVERVIEW**

### **5.1 Asbestos Regulations**

NESHAP (40 CFR Part 61, Subpart M) regulates asbestos fiber emissions and asbestos waste disposal practices. It also requires the identification and classification of existing building materials prior to demolition or renovation activity. Under NESHAP, asbestos-containing building materials are classified as either friable, Category I non-friable, or Category II non-friable ACM. Category I non-friable ACM includes packings, gaskets, resilient floor coverings and asphalt roofing products containing more than 1% asbestos. Category II non-friable ACM are any materials other than Category I materials that contain more than 1% asbestos.

Friable ACM, Category I and Category II non-friable ACM which are in poor condition and have become friable or which will be subjected to drilling, sanding, grinding, cutting or abrading and which could be crushed or pulverized during anticipated renovation or demolition activities are considered Regulated ACM (RACM).

### **5.2 Coating Material and Lead Based Paint Regulations**

Lead-based paint (LBP) is defined as a surface coating or paint containing lead in excess of 0.5% (5000 mg/Kg) by weight (EPA Toxic Substance Control Act, Section 401).

Under EPA regulations heavy metal impacted wastes generated during abatement activities are handled as either a solid waste or a hazardous waste, depending on the concentration of each of the metal(s) and the method of coating material removal.

## **6.0 FINDINGS AND RECOMMENDATIONS**

## 6.1 Suspect Asbestos Containing Materials

A total of 13 bulk samples were collected from five homogeneous areas of suspect ACM. No Asbestos Containing Materials were identified.

A bridge Location Map is included in Appendix A. A photographic log showing homogenous areas is presented in Appendix B. Asbestos analytical results are included in Appendix C. A summary of the suspect ACMs identified is provided in Table 2.

**Table 2 – Summary of Suspected ACM**

Homogeneous Sampling Area	Sample Number	Material Description/Sample Location	Asbestos Results <sup>(1)</sup> , %	NESHAAP Category <sup>(2)</sup>	Friability <sup>(3)</sup>
A	Para-1	concrete parapet	Not detected	N/A	non-friable
	Para-2				
	Para-3				
B	Bridge-1	concrete bridge deck and beams	Not detected	N/A	non-friable
	Bridge-2				
	Bridge-3				
C	Abut-1	concrete abutment	Not detected	N/A	non-friable
	Abut-2				
	Abut-3				
D	Pier-1	concrete piers	Not detected	N/A	non-friable
	Pier-2				
	Pier-3				
E	Text-890EW	white coating material	Not detected	N/A	non-friable

notes: (1) PLM unless otherwise noted.

(2) NESHAAP category I, category II, RACM, or (N/A) not applicable.

(3) Friable materials are those that, when dry, may be crumbled, pulverized or reduced to powder by hand pressure.

*Additional suspect materials, other than those identified during the survey, could exist within the structures in areas not accessible to the inspector at the time of the survey. Should suspect materials other than those identified during this survey be uncovered during the renovation/demolition process, those materials should be assumed to be ACM until sampling and analysis can confirm or refute this assumption.*

## 6.2 Coating Materials

One composite texture sample from the white coating material applied to the concrete parapets identified as “Text-581” was collected for analysis. The composite sample was analyzed for total arsenic, barium, cadmium, chromium, lead, selenium, and silver. Based on the EPA’s definition of LBP, the coating material is not a LBP.

Analytical results are included in Appendix D and laboratory results are summarized in Table 3.

**Table 3 – Summary of Coating Material**

Sample Identification	Material Description/Sample Location	Heavy Metal Results <sup>(1)</sup> , mg/Kg						
		As	Ba	Cd	Cr	Pb	Se	Ag
Text 890EW	parapet texturing	19	470	nd	22	nd	nd	nd

notes: (1) EPA test method 6020.

nd – not detected above method limits.

### **6.3 Recommendations**

No ACMs were identified. Based on the presence metals in coating material, any activities which could result in exposure to workers should be performed in accordance with OSHA regulations to protect workers.

**Appendix A**  
**Bridge Location Map**

Bridge B-581  
Humboldt River, State Route-278  
Carlin, NV





**Appendix B**  
**Bridge Photo Log**

**PHOTOGRAPHIC DOCUMENTATION**

**Bridge B-581  
Humboldt River, SR-278  
Carlin, NV**

**PHOTO 1**

**DATE:**  
07/6/2021

**DIRECTION:**  
Northwest

**TAKEN BY:**  
Robert Piekarz

**DESCRIPTION:**  
Bridge and piers



**PHOTO 2**

**DATE:**  
07/6/2021

**DIRECTION:**  
North

**TAKEN BY:**  
Robert Piekarz

**DESCRIPTION:**  
Bridge deck



**PHOTOGRAPHIC DOCUMENTATION**  
**Bridge B-581**  
**Humboldt River, SR-278**  
**Carlin, NV**

**PHOTO 3**

**DATE:**  
07/6/2021

**DIRECTION:**  
Southeast

**TAKEN BY:**  
Robert Piekarz

**DESCRIPTION:**  
Bridge



**PHOTO 4**

**DATE:**  
07/6/2021

**DIRECTION:**  
North

**TAKEN BY:**  
Robert Piekarz

**DESCRIPTION:**  
Bridge beam, back wall, and parapet



**PHOTOGRAPHIC DOCUMENTATION**  
**Bridge B-581**  
**Humboldt River, SR-278**  
**Carlin, NV**

**PHOTO 5**

**DATE:**  
07/6/2021


**DIRECTION:**  
South

**TAKEN BY:**  
Robert Piekarz

**DESCRIPTION:**  
Bridge beam, pier,  
and parapet



**Appendix C**  
**Asbestos Sample(s)**  
**Analytical Results**



**ASBESTOS TEM LABORATORIES, INC.**

**EPA Method 600/R-93/116  
Polarized Light Microscopy  
Analytical Report**

**Report No. 144906**

1350 Freeport Blvd., Unit 104  
Sparks, NV 89431  
(775) 359-3377  
FAX (775) 359-2798

*Main Office Located At:*  
3431 Ettie Street Oakland, CA 94608  
Ph. (510) 704-8930 Fax (510) 704-8929

---



ASBESTOS TEM LABORATORIES, INC



NVLAP Lab Code 200104-0

Jul-11-21

Mr. Robert Piekarz  
Nevada Department of Transportation  
1263 South Stewart Street  
Carson City, NV 89712

RE: LABORATORY JOB # 9092-00063  
Polarized light microscopy analytical results for 13 bulk sample(s).  
Job Site: Bridge B-581, Humbolt River-SR278  
Job No.: 74329  
Report No.: 144906

Enclosed please find the bulk material analytical results for one or more samples submitted for asbestos analysis. The analyses were performed in accordance with EPA Method 600/R-93/116 or 600/M4-82-020 for the determination of asbestos in bulk building materials by polarized light microscopy (PLM). Please note that while PLM analysis is commonly performed on non-friable and fine grained materials such as floor tiles and dust, the EPA method recognizes that PLM is subject to limitations. In these situations, accurate results may only be obtainable through the use of more sophisticated and accurate techniques such as transmission electron microscopy (TEM) or X-ray diffraction (XRD).

Prior to analysis, samples are logged-in and all data pertinent to the sample recorded. The samples are checked for damage or disruption of any chain-of-custody seals. A unique laboratory ID number is assigned to each sample. A hard copy log-in sheet containing all pertinent information concerning the sample is generated. This and all other relevant paper work are kept with the sample throughout the analytical procedures to assure proper analysis.

Each sample is opened in a class 100 HEPA negative air hood. A representative sampling of the material is selected and placed onto a glass microscope slide containing a drop of refractive index oil. The glass slide is placed under a polarizing light microscope where standard mineralogical techniques are used to analyze and quantify the various materials present, including asbestos. The data is then compiled into standard report format and subjected to a thorough quality assurance check before the information is released to the client.

Please note all samples will be held for 3 months from the date of receipt unless otherwise requested by client.

Sincerely Yours,

Laboratory Analyst  
ASBESTOS TEM LABORATORIES, INC.

--- These results relate only to the samples tested and must not be reproduced, except in full, with the approval of the laboratory. This report must not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. ---



NVLAP Lab Code 200104-0

# POLARIZED LIGHT MICROSCOPY ANALYTICAL REPORT

EPA Method 600/R-93/116 or 600/M4-82-020

Page: 1 of 2

Contact: Mr. Robert Piekarz	Samples Indicated: 13	Report No. <b>144906</b>
Address: Nevada Department of 1263 South Stewart Street Carson City, NV 89712	Reg. Samples Analyzed: 13	Date Submitted: Jul-08-21
	Split Layers Analyzed: 0	Date Reported: Jul-11-21
Job Site / No. Bridge B-581, Humbolt River-SR278 74329		

SAMPLE ID	ASBESTOS % TYPE	OTHER DATA	DESCRIPTION
		1) Non-Asbestos Fibers 2) Matrix Materials 3) Date/Time Collected 4) Date Analyzed	FIELD LAB
Text. Lab ID # 9092-00063-001	<b>None Detected</b>	1) 1-5% Cellulose 2) 95-99% Bndr, Calc, Qtz, Other m.p.	White Coating Materials, Parapet
		3) _____ 4) Jul-11-21	Coating-White/Tan
Para-1. Lab ID # 9092-00063-002	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Parapet
		3) _____ 4) Jul-11-21	Concrete-Grey
Para-2. Lab ID # 9092-00063-003	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Parapet
		3) _____ 4) Jul-11-21	Concrete-Grey
Para-3. Lab ID # 9092-00063-004	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Parapet
		3) _____ 4) Jul-11-21	Concrete-Grey
Bridge-1. Lab ID # 9092-00063-005	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Bridge Spans and Bridge Deck
		3) _____ 4) Jul-11-21	Concrete-Grey
Bridge-2. Lab ID # 9092-00063-006	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Bridge Spans and Bridge Deck
		3) _____ 4) Jul-11-21	Concrete-Grey
Bridge-3. Lab ID # 9092-00063-007	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Bridge Spans and Bridge Deck
		3) _____ 4) Jul-11-21	Concrete-Grey
Abut-1. Lab ID # 9092-00063-008	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Abutment
		3) _____ 4) Jul-11-21	Concrete-Grey
Abut-2. Lab ID # 9092-00063-009	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Abutment
		3) _____ 4) Jul-11-21	Concrete-Grey
Abut-3. Lab ID # 9092-00063-010	<b>None Detected</b>	1) <1% Cellulose 2) 100-100% Clay, Calc, Qtz, Other	Abutment
		3) _____ 4) Jul-11-21	Concrete-Grey

Limit of quantitation of method is estimated to be 1% asbestos using a visual area estimation technique. Split samples are inhomogeneous.

Laboratory Analyst   
Greg Hanes





NVLAP Lab Code 200104-0

# POLARIZED LIGHT MICROSCOPY ANALYTICAL REPORT

EPA Method 600/R-93/116 or 600/M4-82-020

Page: 2 of 2

Contact: Mr. Robert Piekarz	Samples Indicated: 13	Report No. <b>144906</b>
Address: Nevada Department of 1263 South Stewart Street Carson City, NV 89712	Reg. Samples Analyzed: 13	Date Submitted: Jul-08-21
	Split Layers Analyzed: 0	Date Reported: Jul-11-21
Job Site / No. Bridge B-581, Humbolt River-SR278 74329		

SAMPLE ID	ASBESTOS % TYPE	OTHER DATA	DESCRIPTION
		1) Non-Asbestos Fibers 2) Matrix Materials 3) Date/Time Collected 4) Date Analyzed	FIELD LAB
Pier-1.  Lab ID # 9092-00063-011	<b>None Detected</b>	1) <1% Cellulose	Bridge Pier
		2) 100-100% Clay, Calc, Qtz, Other	
		3)	Concrete-Grey
		4) Jul-11-21	
Pier-2.  Lab ID # 9092-00063-012	<b>None Detected</b>	1) <1% Cellulose	Bridge Pier
		2) 100-100% Clay, Calc, Qtz, Other	
		3)	Concrete-Grey
		4) Jul-11-21	
Pier-3.  Lab ID # 9092-00063-013	<b>None Detected</b>	1) <1% Cellulose	Bridge Pier
		2) 100-100% Clay, Calc, Qtz, Other	
		3)	Concrete-Grey
		4) Jul-11-21	
Lab ID #		1)	
		2)	
		3)	
		4)	
Lab ID #		1)	
		2)	
		3)	
		4)	
Lab ID #		1)	
		2)	
		3)	
		4)	
Lab ID #		1)	
		2)	
		3)	
		4)	
Lab ID #		1)	
		2)	
		3)	
		4)	

Limit of quantitation of method is estimated to be 1% asbestos using a visual area estimation technique. Split samples are inhomogeneous.

Laboratory Analyst   
Greg Hanes

### Survey Data

Inspectors: Robert Piekarz		Project Name: Humboldt River-SR278		Project Number: 74329		Date Sampled: 7/6/2021	
Phone: 888-7692		Project Location: Bridge B-581		Analysis Type: Abestos		Air Bulk	
E-mail: <a href="mailto:rpiekarz@dot.nv.gov">rpiekarz@dot.nv.gov</a>		Requests: Verbal		Test to First Positive:		Yes	
Rush 24-Hour 2 Day		Sample Location		Quantity		Friable	
ib #	Sample ID	Material Description	Location of Materials	Condition	Asbestos %		
	TEXT	white coating materials	parapet				
	Para-1	parapet					
	Para-2	parapet					
	Para-3	parapet					
	Bridge-1	bridge spans and bridge deck					
	Bridge-2	bridge spans and bridge deck					
	Bridge-3	bridge spans and bridge deck					
	Abut-1	abutment					
	Abut-2	abutment					

Comments/Additional Information

MATERIAL	CONDITION	UNITS	ASBESTOS %
I - Pipe Fitted Insulation I - Pipe Run Insulation - Duct Insulation - Tank Insulation - Expansion Joint - Boiler Insulation	G - Good D - Damaged SD - Significant Damage	LF - Linear Feet SF - Square Feet CF - Cubic Feet	A - Asbestos C - Chrysotile Asbestos NDA - No Asbestos Detected Assumed ACM - No Samples Taken
VT - Vinyl Tile M - Mastic CBM - Cove Base Mastic AT - Acoustical Tile SA - Spray Acoustic W - Wall P - Plaster JC - Joint Compound	GA - Gasket D - Debris TSI - Thermal System Insulation R - Roof DW - Drywall		

Relinquished By: [Signature] Date/Time: 7/9 0900  
 Relinquished By: \_\_\_\_\_ Date/Time: \_\_\_\_\_  
 Received By: [Signature] Received By: \_\_\_\_\_

### Survey Data

Spectors: Robert Piekarz		Project Name: Humboldt River-SR278		Project Number: 74329		Date Sampled: 7/6/2021	
Phone: 888-7692		Project Location: Bridge B-581		Analysis Type: Asbestos		Air Bulk	
Email: rpiekarz@dot.nv.gov		Requests: Verbal		email		Test to First Positive:	
Form-A-Round Time: Rush 24-Hour 2 Day		Sample Location		Quantity		Condition	
Material Description		Location of Materials		Friable		Asbestos %	
Abut-3	abutment						
Pier-1	bridge pier						
Pier-2	bridge pier						
Pier-3	bridge pier						
Comments/Additional Information							

MATERIAL	CONDITION	UNITS	ASBESTOS %
I - Pipe Fitted Insulation I - Pipe Run Insulation Duct Insulation Tank Insulation Expansion Joint Boiler Insulation	G - Good D - Damaged SD - Significant Damage	LF - Linear Feet SF - Square Feet CF - Cubic Feet	A - Asbestos C - Chrysotile Asbestos NDA - No Asbestos Detected Assumed ACM - No Samples Taken

Relinquished By: _____	Relinquished By: _____
Date/Time: 7/9/09 09:00	Date/Time: _____
Received By: _____	Received By: _____

**Appendix D**  
**Material Coating Sample(s)**  
**Analytical Results**



Alpha Analytical, Inc.  
255 Glendale Ave, #21  
Sparks, Nevada 89431  
TEL: (775) 355-1044 FAX: (775) 355-0406  
Website: [www.alpha-analytical.com](http://www.alpha-analytical.com)

July 16, 2021

Robert Piekarz  
Nevada DOT Environmental (NDOT)  
1263 S. Stewart St.  
Carson City, NV 89712  
TEL: (775) 888-7692  
FAX: (775) 888-7104

RE:

Order No.: NDO2107039

Dear Robert Piekarz:

The result of this report apply to the sample(s) as received.

There were no problems with the analytical events associated with this report unless noted.

Quality control data is within laboratory defined or method specified acceptance limits except if noted.

If you have any questions regarding these tests results, please feel free to call.

Sincerely,

A handwritten signature in cursive script that reads "Randy Gardner".

Randy Gardner  
Laboratory Manager  
255 Glendale Ave, #21  
Sparks, Nevada 89431



Alpha Analytical, Inc.  
255 Glendale Ave, #21  
Sparks, Nevada 89431  
TEL: (775) 355-1044 FAX: (775) 355-0406  
Website: www.alpha-analytical.com

# Analytical Report

WO#: NDO2107039

Report Date: 7/16/2021

**CLIENT:** Nevada DOT Environmental (NDOT)

**Collection Date:** 7/6/2021 1:00:00 PM

**Project:**

**Lab ID:** 2107039-03

**Matrix:** OTHER

**Client Sample ID:** TEXT-581

Analyses	Result	RL	Qual	Units	Date Analyzed	Method
Chromium (Cr)	22	1.0		mg/Kg	7/12/2021	Metals by EPA 6020
Arsenic (As)	19	1.0		mg/Kg	7/12/2021	Metals by EPA 6020
Selenium (Se)	ND	2.0		mg/Kg	7/12/2021	Metals by EPA 6020
Silver (Ag)	ND	1.0		mg/Kg	7/12/2021	Metals by EPA 6020
Cadmium (Cd)	ND	1.0		mg/Kg	7/12/2021	Metals by EPA 6020
Barium (Ba)	470	1.0		mg/Kg	7/12/2021	Metals by EPA 6020
Lead (Pb)	ND	1.0		mg/Kg	7/12/2021	Metals by EPA 6020



Alpha Analytical, Inc.  
 255 Glendale Ave, #21  
 Sparks, Nevada 89431  
 TEL: (775) 355-1044 FAX: (775) 355-0406  
 Website: www.alpha-analytical.com

# QC SUMMARY REPORT

WO#: 2107039

16-Jul-21

**Client:** Nevada DOT Environmental (NDOT)

**Project:**

**TestCode:** METALS\_SO

Sample ID: <b>MB-13295</b>	SampType: <b>MBLK</b>	TestCode: <b>METALS_SO</b>	Units: <b>mg/Kg</b>
Client ID: <b>PBS</b>	Batch ID: <b>13295</b>	TestNo: <b>E200.8</b>	
Prep Date: <b>7/9/2021</b>	RunNo: <b>11948</b>	SeqNo: <b>333120</b>	
Analysis Date: <b>7/12/2021</b>			

Analyte	Result	PQL	SPK Value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Chromium (Cr)	ND	1									
Arsenic (As)	ND	1									
Selenium (Se)	ND	2									
Silver (Ag)	ND	1									
Cadmium (Cd)	ND	1									
Barium (Ba)	ND	1									
Lead (Pb)	ND	1									

Sample ID: <b>LCS-13295</b>	SampType: <b>LCS</b>	TestCode: <b>METALS_SO</b>	Units: <b>mg/Kg</b>
Client ID: <b>LCSS</b>	Batch ID: <b>13295</b>	TestNo: <b>E200.8</b>	
Prep Date: <b>7/9/2021</b>	RunNo: <b>11948</b>	SeqNo: <b>333121</b>	
Analysis Date: <b>7/12/2021</b>			

Analyte	Result	PQL	SPK Value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Chromium (Cr)	54	1	50	0	108	79.51	120.49				
Arsenic (As)	52.9	1	50	0	106	79.51	120.49				
Selenium (Se)	53.2	2	50	0	106	79.51	120.49				
Silver (Ag)	53.4	1	50	0	107	79.51	120.49				
Cadmium (Cd)	50.6	1	50	0	101	79.51	120.49				
Barium (Ba)	50.2	1	50	0	100	79.51	120.49				
Lead (Pb)	45.7	1	50	0	91.4	79.51	120.49				

Sample ID: <b>2107039-01AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>METALS_SO</b>	Units: <b>mg/Kg</b>
Client ID: <b>TEXT-862MSD</b>	Batch ID: <b>13295</b>	TestNo: <b>E200.8</b>	
Prep Date: <b>7/9/2021</b>	RunNo: <b>11948</b>	SeqNo: <b>333124</b>	
Analysis Date: <b>7/12/2021</b>			

Analyte	Result	PQL	SPK Value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Chromium (Cr)	85.8	1	50	43.8	84.0	69.51	130.49	85.2	0.72	20	
Arsenic (As)	43.7	1	50	9.41	68.7	69.51	130.49	50.9	15	20	S
Selenium (Se)	45.8	2	50	0	91.6	69.51	130.49	47.1	2.8	20	
Silver (Ag)	52.4	1	50	0	105	69.51	130.49	54.1	3.2	20	
Cadmium (Cd)	49.8	1	50	0	99.5	69.51	130.49	50.3	1	20	
Barium (Ba)	1860	1	50	1020	1,680	69.51	130.49	1350	32	20	RS
Lead (Pb)	342	1	50	2370	-4,050	69.51	130.49	132	89	20	RS

**Qualifiers:** B Analyte detected in the associated Method Blank  
 ND Not Detected at the Reporting Limit  
 R RPD outside accepted recovery limits  
 S Spike Recovery outside accepted recovery limits



Alpha Analytical, Inc.  
 255 Glendale Ave, #21  
 Sparks, Nevada 89431  
 TEL: (775) 355-1044 FAX: (775) 355-0406  
 Website: www.alpha-analytical.com

# QC SUMMARY REPORT

WO#: 2107039

16-Jul-21

**Client:** Nevada DOT Environmental (NDOT)

**Project:**

**TestCode:** METALS\_SO

Sample ID: <b>2107039-01AMS</b>	SampType: <b>MS</b>	TestCode: <b>METALS_SO</b>	Units: <b>mg/Kg</b>
Client ID: <b>TEXT-862MS</b>	Batch ID: <b>13295</b>	TestNo: <b>E200.8</b>	
Prep Date: <b>7/9/2021</b>	RunNo: <b>11948</b>	SeqNo: <b>333123</b>	
Analysis Date: <b>7/12/2021</b>			

Analyte	Result	PQL	SPK Value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Chromium (Cr)	85.2	1	50	43.8	82.7	69.51	130.49				
Arsenic (As)	50.9	1	50	9.41	83.0	69.51	130.49				
Selenium (Se)	47.1	2	50	0	94.2	69.51	130.49				
Silver (Ag)	54.1	1	50	0	108	69.51	130.49				
Cadmium (Cd)	50.3	1	50	0	101	69.51	130.49				
Barium (Ba)	1350	1	50	1020	659	69.51	130.49				S
Lead (Pb)	132	1	50	2370	-4,470	69.51	130.49				S

**Qualifiers:** B Analyte detected in the associated Method Blank  
 ND Not Detected at the Reporting Limit  
 R RPD outside accepted recovery limits  
 S Spike Recovery outside accepted recovery limits





Alpha Analytical, Inc.  
255 Glendale Ave, #21  
Sparks, Nevada 89431  
TEL: (775) 355-1044 FAX: (775) 355-0406  
Website: [www.alpha-analytical.com](http://www.alpha-analytical.com)

## Definition Only

WO#: 2107039  
Date: 7/16/2021

---

### Definitions:

ND = Not Detected

C = Reported concentration includes additional compounds uncharacteristic of common fuels and lubricants.

D = Reporting Limits were increased due to high concentrations of non-target analytes.

H = Reporting Limits were increased due to the hydrocarbons present in the sample.

J = The analyte was positively identified; the associated numerical value is the approximate concentration of the analyte in the sample.

K = DRO concentration may include contributions from lighter-end hydrocarbons (e.g. gasoline) that elute in the DRO range.

L = DRO concentration may include contributions from heavier-end hydrocarbons (e.g. motor oil) that elute in the DRO range.

O = Reporting Limits were increased due to sample foaming.

V = Reporting Limits were increased due to high concentrations of target analytes.

X = Reporting Limits were increased due to sample matrix interferences.

Z = DRO concentration may include contributions from lighter-end (e.g. gasoline) and heavier-end (e.g. motor oil) hydrocarbons that elute in the DRO range.

S50 = The analysis of the sample required a dilution such that the surrogate concentration was diluted below the laboratory acceptance criteria. The laboratory control sample was acceptable.

S51 = Surrogate recovery could not be determined due to the presence of co-eluting hydrocarbons.

S52 = Surrogate recovery was above laboratory acceptance limits. Probable matrix effect.

S53 = Surrogate recovery was below laboratory acceptance limits. Probable matrix effect.

S54 = Surrogate recovery was below laboratory acceptance limits.

S55 = Surrogate recovery was above laboratory acceptance limits.

# WORKORDER SUMMARY

NV

## Alpha Analytical, Inc.

255 Glendale Ave, #21 Sparks, Nevada 89431

TEL: (775) 355-1044 FAX: (775) 355-0406

WorkOrder: NDO2107039  
 Report Due By: 22-Jul-21  
 EDD Required: NO

**Report Attention:** Robert Piekarz

**Client:**


Nevada DOT Environmental (NDOT)  
 1263 S. Stewart St.  
 Carson City, NV 89712

TEL: 7758887692  
 FAX: 7758887104  
 ProjectNo:

**Date Received:** 08-Jul-21

Alpha Sample ID	Client Sample ID	Matrix	Collection Date	No. of Bottles			Requested Tests							Sample Remarks		
				Alpha	Sub	TAT	METALS_SO									
NDO2107039-01	TEXT-862	OTHER	7/6/2021 9:00:00 AM	1	0	10	A - As, Ba, Cd, Cr, Pb, Ag, Se									
NDO2107039-02	TEXT-1011	OTHER	7/6/2021 11:00:00 AM	1	0	10	A - As, Ba, Cd, Cr, Pb, Ag, Se									
NDO2107039-03	TEXT-581	OTHER	7/6/2021 1:00:00 PM	1	0	10	A - As, Ba, Cd, Cr, Pb, Ag, Se									

**Comments:** Samples in plastic bags.

Signature	Print Name	Company	Date/Time
	Haylee Tilton	Alpha Analytical, Inc.	7/8/21 1351

NOTE: Samples are discarded 60 days after sample receipt unless other arrangements are made. Hazardous samples will be returned to client or disposed of at client expense.

**Billing Information:**  
 Company: Nevada Department of Transportation  
 Attn: Robert Piekarz  
 Address: 1263 South Stewart  
 City, State, Zip: Carson City, NV 89712  
 Phone Number: 775-888-7692 Fax: 775-888-7104



**Alpha Analytical, Inc.**  
 Main Laboratory: 255 Glendale Ave, Suite 21 Sparks, NV 89431  
**Satellite Service Centers:**  
 Northern CA: 9891 Horn Road, Suite C, Rancho Cordova, CA 95827  
 Southern NV: 6255 McLeod Ave, Suite 24, Las Vegas, NV 89120  
 Southern CA: 1007 E. Dominguez St., Suite O, Carson, CA 90746

Phone: 775-355-1044  
 Fax: 775-355-0406  
 Phone: 916-366-9089  
 Phone: 702-736-7522  
 Phone: 310-803-7761

<b>Consultant/ Client Info:</b> Company: <u>As above</u> Address: _____ City, State, Zip: _____	<b>Job and Purchase Order Info:</b> Job # <u>N.A.</u> Job Name: _____ P.O. #: _____	<b>Report Attention/Project Manager:</b> Name: <u>Robert Piekarz</u> Email Address: <u>rpiekarz@dot.nv.gov</u> Phone #: <u>775-888-7692</u> Cell #: _____	<b>QC Deliverable Info:</b> EDD Required? Yes / No _____ EDF Required? Yes / No _____ Global ID: _____ Data Validation Level: _____ III or IV
--	--	---	--

Samples Collected from which State? (circle one) AZ CA NV WA ID OR DOD Site Other

Time Sampled (HHMM)	Date Sampled (MM/DD)	Matrix* (See Key Below)	Lab ID Number (For Lab Use Only)	Sample Description	TAT	Field Filtered?	# Containers** (See Key Below)	RCRA 7 Metals, total	Analysis Requested										Remarks		
09:00	7/6/21	OT	<u>NDS 2107039-01</u>	TEXT-862	STD	No	1-OT	X													
11:00	"	"	<u>02</u>	TEXT-1011	"	"	"	X													
13:00	"	"	<u>03</u>	TEXT-581	"	"	"	X													

**ADDITIONAL INSTRUCTIONS:**  
 \_\_\_\_\_  
 \_\_\_\_\_

I (field sampler) attest to the validity and authenticity of this sample(s). I am aware that tampering with or intentionally mislabeling the sample location, date or time of collection is considered fraud and may be grounds for legal action. NAC 445.0636 (c) (2).

Sampled By: <u>[Signature]</u>	Date: <u>7/8</u>	Time: <u>0900</u>	Received by: <u>[Signature]</u>	Date: <u>7/8/21</u>	Time: <u>9:00</u>
Relinquished by: <u>[Signature]</u>	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____
Relinquished by: _____	Date: _____	Time: _____	Received by: _____	Date: _____	Time: _____

\* Key: AQ - Aqueous WA - Waste OT - Other \*\*: L - Liter V - VOA S - Soil Jar O - Orbo T - Tedlar B - Brass P - Plastic OT - Other  
 NOTE: Samples are discarded 60 days after sample receipt unless other arrangements are made. Hazardous samples will be returned to client or disposed of at client expense. The report for the analysis of the above samples is applicable only to those samples received by the laboratory with this COC. The liability of the laboratory is limited to the amount paid for the report.

**Appendix E**  
**Inspector Certifications**  
**and**  
**Licenses**

*mm*


**STATE OF NEVADA**  
**DEPARTMENT OF BUSINESS AND INDUSTRY**  
**DIVISION OF INDUSTRIAL RELATIONS**  
**Occupational Safety and Health Administration**  
**Asbestos Control Program**

Certifies That Robert Piekarz  
State of Nevada-DOT  
is Licensed As Asbestos Abatement Consultant

License No. IJ-1049

Expiration Date 11/24/2021

Signature Of Licensee \_\_\_\_\_



**STATE OF NEVADA**  
**DEPARTMENT OF BUSINESS AND INDUSTRY**  
**DIVISION OF INDUSTRIAL RELATIONS**  
**Occupational Safety and Health Administration**  
**Asbestos Control Program**

*mm*

Certifies That Robert Piekarz  
State of Nevada-DOT  
is Licensed As Asbestos Abatement Consultant

License No. IJ-1049      Expiration Date 11/24/2021

Signature Of Licensee \_\_\_\_\_

# M & C Environmental Training

**Asbestos Inspector**  
Refresher Training Course

**Robert Piekarz**

Has successfully completed the Asbestos Inspector Refresher course approved by the California Division of Occupational Safety and Health for purposes of certification required by Title 8, Article 2.7, Chapter 3.2, Section 341.16 and the accreditation required under the Toxic Substances Control Act, Title II. Conducted by M&C Environmental Training Inc., P.O. Box 6419, Concord, California Tel. # (510) 499-5646

Course Approval Number: CA-003-06

Location:	Concord, California	Expiration:	November 24, 2021
Dates:	November 24, 2020		
Director of Training:	John McGinnis		



Certificate Number **48309 IR**

# M & C Environmental Training

## Asbestos Management Planner

Refresher Training Course

**Robert Piekarz**

Has successfully completed the Asbestos Management Planner Refresher course approved by the California Division of Occupational Safety and Health for purposes of certification required by Title 8, Article 2.7, Chapter 3.2, Section 341.16 and the accreditation required under the Toxic Substances Control Act, Title II. Conducted by M&C Environmental Training Inc., P.O. Box 6419, Concord, California. Tel. # (510) 499 - 5646

Course Approval Number: CA-003-08

Location: Concord, California

Expiration: November 24, 2021

Dates: November 24, 2020

Director of Training: John McGinnis



Certificate Number 48327 PR